

Water Analysis Report

Lab Number : 29

Results For :

Sample ID :

Location : Baton Rouge

pH 8.7

Total Dissolved Solids (TDS) Est, ppm 193

Electrical Conductivity, mmho/cm 0.32

Cations / Anions, me/L 3.0/ 3.5

ppm

Sodium, Na 67

Potassium, K < 1

Calcium, Ca 2

Magnesium, Mg < 1

Total Hardness, CaCO₃ 5

Nitrate, NO₃-N < 0.1 (SAFE)

Sulfate, SO₄-S 3

Chloride, Cl 6

Carbonate, CO₃ 12

Bicarbonate, HCO₃ 168

Total Alkalinity, CaCO₃ 159

Total Phosphorus, P 0.45

Total Iron, Fe < 0.01

"<" - Not Detected / Below Detection Limit

Reviewed By :

Joshua Skrdla 1/7/2014

Bus: 308-234-2418

4007 Cherry Ave.,

P.O. Box 788

Kearney, Nebraska 68848-0788

www.wardlab.com

WARD Laboratories, Inc.