

Account No. : 600403

Water Analysis Report

ALLEN, LLOYD  
37557 IRVING AVE  
PRAIRIEVILLE LA 70769

Invoice No. : 1375292  
Date Received : 07/05/2022  
Date Reported : 07/06/2022  
Lab Number : 9089

Results For : LLOYD ALLEN

Location :

Sample ID :

pH	8.4
Total Dissolved Solids (TDS) Est, ppm	176
Electrical Conductivity, mmho/cm	0.29
Cations / Anions, me/L	2.8 / 3.0

	<u>ppm</u>
Sodium, Na	64
Potassium, K	< 1
Calcium, Ca	1.0
Magnesium, Mg	< 1
Total Hardness, CaCO <sub>3</sub>	3
Nitrate, NO <sub>3</sub> -N	0.5 (SAFE)
Sulfate, SO <sub>4</sub> -S	3
Chloride, Cl	7
Carbonate, CO <sub>3</sub>	2.4
Bicarbonate, HCO <sub>3</sub>	151
Total Alkalinity, CaCO <sub>3</sub>	127
Total Phosphorus, P	0.41
Total Iron, Fe	< 0.01

"<" - Not Detected / Below Detection Limit